

CROSS CONNECTION AND BACKFLOW



AGGREGATE
WATER SERVICES

CROSS CONNECTION

A physical connection between potable drinking water and another liquid or gas contaminant.

BACKFLOW

Water that is flowing in the opposite direction than what is intended. This can happen if pressure is lost on either side of the connection, customer or supplier.

How Can You Help?

- Staying up to date with the annual TCEQ mandated inspection for your Backflow device performed by a licensed inspector.
- Ensuring that you have a hose bib vacuum breaker on all exterior hose bibs.
- Ensuring that all irrigation systems are outfitted with a state required backflow device.
- Staying up to date with TCEQ requirements provided on the listed website:
www.tceq.gov



If you have any questions, Please
contact Aggregate Water Services



936-321-7721



Aggregatewater.com